

2024 ANNUAL DRINKING WATER QUALITY REPORT

Fishertown Water Association

PWSID #: 4050029

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report concerning your water utility, please contact James Bud Ratchford at (814) 839-4032. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the 3rd Tuesday of every month at 3:30 PM in the Fishertown Water Association office unless posted as different.

SOURCE OF WATER:

Our water source is a well located in Chestnut Ridge along TR 681

A *Source Water Assessment* of our source was completed in 2008 by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our source is potentially most susceptible to road deicing materials, accidental spills along roads, and leaks in underground storage tanks. Overall, our source has little risk of significant contamination. A summary report of the Assessment is available on the *Source Water Assessment and protection Web Page* at (<http://www.dep.state.pa.us/dep/deputate/watermgt/wc/Subjects/SrceProt/SourceAssessment/default.htm>). Complete reports were distributed to municipalities, water supplier, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Altoona Regional Office, Records Management Unit at (814)946-7292.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2024. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppt (ng/l) = parts per trillion, or nanograms per liter

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL	MCLG	Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Barium	2	2	0.0497	N/A	ppm	4/22/24	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Nitrate	10	10	2.53	N/A	ppm	1/3/24	N	Runoff from fertilizer use; leaching from septic tanks, sewage; Erosion of natural deposits
Chlorine (Distribution)	MRDL =4	MRDLG =4	1.27 (April 2024)	0.89-1.27	ppm	2024 Weekly	N	Water additive used to control microbes

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine (2024)	0.40	0.80	0.80-1.82	ppm	6/22/24	N	Water additive used to control microbes.

Lead and Copper 2022								
Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Range of Tap Sampling Results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	0.60	0.00-0.668	ppb	0 out of 10	N	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	1.3	1.3	0.206	0.0205-0.282	ppm	0 out of 10	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Fishertown Water Association is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact The Fishertown Water Association at (814) 839-4032. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

The Fishertown Water Association prepared a service line inventory that includes the type of material contained in each service line in our distribution system. This inventory can be accessed by contacting our office at 814-839-4032.

Violations: In the 3rd quarter of 2024 we monitored for Perfluorooctanoic acid (PFOA) and Perfluorooctanesulfonic acid (PFOS) but failed to report the results to the PA Department of Environmental Protection by the required due date resulting in monitoring/reporting violations.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Fifth Unregulated Contaminant Monitoring Rule

The Safe Drinking Water Act (SDWA) requires that once every five years the EPA issue a list of unregulated contaminants to be monitored by public water systems.

The fifth Unregulated Contaminant Monitoring Rule (UCMR 5) was published on December 27, 2021. UCMR 5 requires sample collection for 30 chemical contaminants between 2023 and 2025. The data collected under UCMR 5 improves understanding of the prevalence and amount of 29 per- and polyfluoroalkyl substances (PFAS) and lithium in the nation's drinking water systems. All systems are required to report their data to EPA. The analytical results from UCMR are stored in the National Contaminant Occurrence Database (NCOD) for drinking water.

The Fishertown Water Association participated in UCMR 5 monitoring, and all of the results were below the Minimum Reporting Level (MRL).

For a summary of the UCMR results, tips for querying NCOD, and health effects information (including reference concentrations), please refer to the UCMR Occurrence Data webpage at: <https://www.epa.gov/dwucmr/occurrence-data-unregulated-contaminant-monitoring-rule>

Where can consumers find UCMR results? <https://www.epa.gov/dwucmr/fifth-unregulated-contaminant-monitoring-rule-data-finder#data-finder>