

2024 ANNUAL DRINKING WATER QUALITY REPORT
PWSID # 6420017 Hazel Hurst Water Company

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Bradley Himes at 814-598-3721. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the 2nd Tuesday every month at 7pm at the firehall.

SOURCE OF WATER:

Our water source is a groundwater well located in Hazel Hurst.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following table shows the results of our monitoring for the period of January 1 to December 31, 2024. The State allows us to monitor some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the *Safe Drinking Water Act*. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant that is allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level (MinRDL) - The minimum level of residual disinfectant required at the entry point to the distribution system.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppq = parts per quadrillion, or picograms per liter

ppt (ng/l) = parts per trillion, or nanograms per liter

pbb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminants								
Contaminant	MCL in CCR Units	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (Distribution)	MRDL= 4	MRDLG = 4	0.81 (January 2024)	0.61 – 0.81	ppm	2024	N	Water additive used to control microbes.
Nitrate	10	10	0.19	N/A	ppm	9/26/24	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Arsenic	10	0	3.50	N/A	ppb	9/30/21	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium	2	2	0.243	N/A	ppm	9/30/21	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Trihalomethanes	80	NA	5.7733 (Average of 3 Samples)	0.00-8.87	ppb	2024	N	By-product of drinking water chlorination
Combined Radium	5	0	0.433 (Average of 3 Samples)	0.00-1.27	(pCi/l)	2024	N	Erosion of natural deposits
Iron*	0.3*	NA*	2.81	0.48-2.81	ppm	2020	N	Naturally occurring mineral
Manganese*	0.05*	NA*	0.045	0.009-0.045	ppm	12/28/23	N	Naturally occurring mineral

DETECTED CONTAMINANTS HEALTH EFFECTS LANGUAGE AND CORRECTIVE ACTIONS

*Iron and Manganese Maximum Contaminant Levels are based on the Secondary Maximum Contaminant Levels as stated in the Safe Drinking Water Act. These contaminants are regulated differently than contaminants on the primary list.

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine 2024 Entry Point #106	0.40	0.58	0.58-1.18	ppm	8/10/24	N	Water additive used to control microbes.

Lead and Copper 2024								
Contaminant	Action Level (AL)	MCL G	90 th Percentile Value	Range of Tap Sampling Results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead 1/1/24-6/30/24 7/1/24-12/31/24	15	0	0.00	0.00-0.00	ppb	0 out of 15	N	Corrosion of household plumbing systems; Erosion of natural deposits
	15	0	0.00	0.00-0.00	ppb	0 out of 15	N	
Copper 1/1/24-6/30/24 7/1/24-12/31/24	1.3	1.3	0.395	0.003-0.55	ppm	0 out of 15	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
	1.3	1.3	0.187	0.00-0.72	ppm	0 out of 15	N	

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hazel Hurst Water Company is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Hazel Hurst Water Company at 814-598-3721. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

Hazel Hurst Water Company is preparing a service line inventory that includes the type of material contained in each service line in our distribution system. This inventory can be accessed by contacting us at 814-598-3721.

Violations: In October of 2024 we failed to report our Distribution and Entry Point Chlorine results to the PA Department of Environmental Protection by the required due dates resulting in Monitoring/Reporting Violations.

In the 2nd quarter of 2024 we failed to monitor for Volatile Organic Chemicals (VOCS), Alpha emitters, Combined Uranium, Radium-226, Radium-228, and monitored for Haloacetic Acids and Trihalomethanes at the wrong location in the 3rd quarter. Public Notification Regarding these Failure to Monitor Violations is enclosed at the end of this report.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater run-off and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater run-off and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to assure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Monitoring Requirements Not Met for the Hazel Hurst Water Company

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In the 2nd quarter of 2024 we failed to monitor for Volatile Organic Chemicals (VOCS), Alpha Emitters, Combined Uranium, Radium-226, Radium-228, and monitored for Haloacetic Acids and Trihalomethanes at the wrong location in the 3rd quarter and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the last year, how often we are supposed to sample for Volatile Organic Chemicals (VOCS), Alpha emitters, Combined Uranium, Radium-226, and Radium-228, Haloacetic Acids, and Trihalomethanes and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Volatile Organic Chemicals (VOCS)*	Each quarter in 2024	0 in 2 nd Quarter of 2024	2 nd Quarter of 2024	7/18/24
Alpha Emitters	Each quarter in 2024	0 in 2 nd Quarter of 2024	2 nd Quarter of 2024	7/18/24
Combined Uranium	Each quarter in 2024	0 in 2 nd Quarter of 2024	2 nd Quarter of 2024	7/18/24
Radium-226	Each quarter in 2024	0 in 2 nd Quarter of 2024	2 nd Quarter of 2024	7/18/24
Radium-228	Each quarter in 2024	0 in 2 nd Quarter of 2024	2 nd Quarter of 2024	7/18/24
Haloacetic Acids	Each quarter in 2024	Sample taken at Wrong Location in 3 rd Quarter of 2024	3 rd Quarter of 2024 at Site #701	4th Quarter of 2024 at Site #701
Trihalomethanes	Each quarter in 2024	Sample taken at Wrong Location in 3 rd Quarter of 2024	3 rd Quarter of 2024 at Site #701	4th Quarter of 2024 at Site #701

(VOCS)*-1,2,4-Trichlorobenzene, Cis-1,2-Dichloroethylene, Xylenes (Total), Dichloromethane, O-Dichlorobenzene, Para-Dichlorobenzene, 1,1-Dichloroethylene, Trans-1,2-Dichloroethylene, 1,2-Dichloroethane, 1,1,1-Trichloroethane, Carbon Tetrachloride, 1,2-Dichloropropane, Trichloroethylene, 1,1,2-Trichloroethane, Tetrachloroethylene, Chlorobenzene, Benzene, Toluene, Ethylbenzene, Styrene

What happened? What was done? *In the 2nd quarter of 2024 we failed to monitor for Volatile Organic Chemicals (VOCS), Alpha emitters, Combined Uranium, Radium-226, Radium-228, and monitored for Haloacetic Acids and Trihalomethanes at the wrong location in the 3rd quarter. Samples were taken in the following quarters.*

For more information, please contact Bradley Himes at 814-598-3721.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you from the Hazel Hurst Water Company.