

2025 ANNUAL DRINKING WATER QUALITY REPORT

PWSID #: 5040036 Industry Borough Municipal Authority

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it or speak with someone who understands it.)

WATER SYSTEM INFORMATION: This report describes our water quality and what it means. We are pleased to report that our drinking water meets federal and state requirements. If you have any questions about this report or concerns regarding your water utility, please contact Industry Borough Municipal Authority at (724-643-9522). We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the fourth Tuesday of the month at 6:00 PM at the Industry Water Authority Building located at 1149 East Willowbrook Drive, Industry, PA.

SOURCES OF WATER: Our water source is ground water from two wells located within the Industry Borough jurisdictional limits. We also have an emergency interconnection with Ohioville Borough. Industry Borough Municipal Authority has a Wellhead Protection Area Delineation and Plan that was completed in September 2007. A complete copy may be viewed at the authority office. Water treatment is limited to chlorination. The water is pumped from the wells to four steel storage tanks: the 100,000-gallon Barclay Hill tank; the 200,000-gallon Allison Drive tank; the 200,000-gallon Engle Road tank; and the 300,000-gallon Willowbrook Drive tank. The final distribution to our customers is by gravity flow from the storage tanks. The aquifer producing the ground water is represented by a glacial outwash valley-fill sequence that occurs within the Ohio River Valley below the Montgomery Dam to 1250 feet above mean sea level at the base on the Willowbrook Drive tank, with the Ohio River Valley representing the primary topographic feature in the area.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER: We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Minimum Residual Disinfectant Level - The minimum level of residual disinfectant required at the entry point to the distribution system.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Level 1 Assessment - A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment - A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g/L}$)

ppm = parts per million, or milligrams per liter (mg/L).

Entry Point Disinfectant Residual							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine (2025)	0.40	0.51	0.51-2.18	ppm	8/6/25	N	Water additive used to control microbes.

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Barium	2	2	0.125	N/A	(ppm)	1/8/24	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium	100	100	3.28	N/A	(ppb)	1/8/24	N	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride	2*	2	0.22	N/A	(ppm)	1/8/24	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nickel	N/A	N/A	0.00222	N/A	(ppm)	1/8/24	N	Leaching from metals in contact with drinking water, erosion in the production of steel alloys.
Iron**								
Entry Point Distribution	SMCL 0.30	N/A	0.02 0.08	0.00-0.02 0.00-0.08	(ppm) (ppm)	2025 2025	N N	Naturally occurring mineral
Manganese**								
Entry Point Distribution	SMCL 0.05	N/A	0.42 0.28	0.07-0.42 0.00-0.28	(ppm) (ppm)	2025 2025	N N	Naturally occurring mineral
Nitrate	10	10	0.64	N/A	(ppm)	1/24/25	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Chlorine (Distribution)	MRDL = 4	MRDLG = 4	0.89 (Dec. 2025)	0.30-0.89	(ppm)	2025	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	60	N/A	5.38	N/A	(ppb)	9/15/25	N	By-product of drinking water disinfection
TTHMs (Total Trihalomethanes)	80	N/A	26.20	N/A	(ppb)	9/15/25	N	By-product of drinking water chlorination
Perfluorooctanesulfonic acid (PFOS)	18	14	4.38	3.54-4.38	(ppt)	2025	N	Discharge from manufacturing facilities and runoff from land use activities
Perfluorooctanoic Acid (PFOA)	14	8	0.454	0-0.454	(ppt)	2025	N	Discharge from manufacturing facilities and runoff from land use activities

*EPA's MCL for fluoride is 4 ppm. However, Pennsylvania has set a lower MCL to better protect human health.

**Iron and Manganese Maximum Contaminant Levels are based on the Secondary Maximum Contaminant Levels (SMCL) as stated in the Safe Drinking Water Act. These contaminants are regulated differently than contaminants on the primary list

Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Range of Tap Sampling Results	Units	# Of Sites Above AL of Total Sites	Violation of TT Y/N	Sources of Contamination
Copper (2025)	1.3	1.3	0.118	0.047-0.205	ppm	0 of 10 Samples	N	Corrosion of household Plumbing; erosion of natural deposits; leaching from wood preservatives.
Lead (2025)	15	0	1.31	0.13-4.32	ppb	0 of 10 Samples	N	Corrosion of household plumbing systems; Erosion of natural deposits

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Industry Borough Municipal Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Industry Borough Municipal Authority at (724-643-9522). Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

A lead service line inventory was completed in 2024, and it was determined there were no lead service lines in our distribution system and numerous lines were determined to be unknown materials To access the service line inventory, contact Industry Borough Municipal Authority at (724-643-9522).

Violations: In 2025, we failed to submit our 2024 Consumer Confidence Report by the required due date. We also reported distribution chlorine for March 31st on June 9th. Distribution chlorine for March 31st was required to be submitted by April 10th, this triggered a reporting violation.

EDUCATIONAL INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, can be naturally occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are by-products of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).