

# 2024 ANNUAL DRINKING WATER QUALITY REPORT

## PWSID #: 6240005, Jay Township Water Authority

*Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda.* (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

### **WATER SYSTEM INFORMATION:**

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact the Authority at 814-787-7233. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held the 1<sup>st</sup> Thursday of each month at 7:00 PM at the Jay Township Office located at 81 E. Teaberry Street Weedville, PA 15868.

### **SOURCES OF WATER:**

Jay Township Water Authority obtains its water from two surface water sources and one groundwater source. The surface water sources, Byrnes Run and Kersey Run, are the primary sources used. The groundwater source, Byrnedale Well #1 is used intermittently, such as when the streams are extremely dirty or when there are issues at the surface treatment plant. These sources are located approximately ½ mile northwest of the Village of Byrnedale.

A Source Water Assessment of our sources was completed by the PA Department of Environmental Protection (Pa. DEP). The Assessment has found that our sources are potentially most susceptible to mining sites and oil/gas wells. Overall, our sources have little risk of significant contamination. A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: [www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045](http://www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045). Complete reports were distributed to municipalities, water suppliers, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Northwest Regional Office, Records Management Unit at (814) 332-6945.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

### **MONITORING YOUR WATER:**

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2024. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

### **DEFINITIONS:**

*Action Level (AL)* - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level (MCL)* - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal (MCLG)* - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Residual Disinfectant Level (MRDL)* - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Maximum Residual Disinfectant Level Goal (MRDLG)* - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Minimum Residual Disinfectant Level (MinRDL)* - The minimum level of residual disinfectant required at the entry point to the distribution system.

*Level 1 Assessment* – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

**Level 2 Assessment** – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Mrem/year** = millirems per year (a measure of radiation absorbed by the body)

**ppm** = parts per million, or milligrams per liter(mg/L)

**pCi/L** = picocuries per liter (a measure of radioactivity)

**ppb** = parts per billion, or micrograms per liter (u(µg/L)

**ppq** = parts per quadrillion, or picograms per liter

**ppt** = parts per trillion, or nanograms per liter

<b>Chemical Contaminants</b>								
<b>Contaminant</b>	<b>MCL</b>	<b>MCLG</b>	<b>Highest Level Detected</b>	<b>Range of Detections</b>	<b>Units</b>	<b>Sample Date</b>	<b>Violation Y/N</b>	<b>Sources of Contamination</b>
Chlorine (Distribution)	MRDL = 4	MRDLG = 4	2.01 April 2024	1.48 – 2.01	ppm	2024	N	Water additive used to control microbes
Haloacetic Acids (HAA5)	60	N/A	8.81 (1st Quarter) <b>(a)</b>	1.17 – 7.12	ppb	2024	N	By-product of drinking water disinfection
Total Trihalomethanes (TTHM)	80	N/A	17.56 (4th Quarter) <b>(a)</b>	4.60 – 45.20	ppb	2024	N	By-product of drinking water chlorination
Barium	2	2	0.976	0-0.976	ppm	5/21/24	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride	<b>2(b)</b>	2	0.15	0-0.15	ppm	5/21/24	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Nitrate	10	10	0.16	0-0.16	ppm	9/17/24	N	Runoff from fertilizer use; Leaching from septic tanks; sewage: Erosion of natural; deposits
Selenium	50	50	1.00	0.00-1.00	ppb	3/22/23	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Uranium	30	0	15.79	14.68-15.79	ppb	2/9/22	N	Erosion of natural deposits
Combined Radium	5	0	1.29	0-1.29	pCi/L	5/21/24	N	Erosion of natural deposits

**(a)** Indicates the highest running annual average calculated during the year 2024.

**(b)** \*EPA's MCL for fluoride is four ppm. However, Pennsylvania has set a lower MCL to better protect human health.

<b>Entry Point Disinfectant Residual 2024</b>							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine	0.20	0.06	0.06-3.00	ppm	1/4/24	Y	Water additive used to control microbes.

<b>Lead and Copper</b>								
Contaminant	Action Level (AL)	MCLG	90 <sup>th</sup> Percentile Value	Range of Tap Sampling Results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead 2024	15	0	17.16	0-32.0	ppb	2 of 14	Y	Corrosion of household plumbing systems; Erosion of natural deposits
Copper 2024	1.3	1.3	0.298	0-0.37	ppm	0 of 14	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

### **Information about Lead**

**Lead:** Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Jay Township Water Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Jay Township Water Authority at 814-787-7233. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

Jay Township Water Authority has not fully completed a lead service line inventory. We expect to have the inventory completed in 2025. If you have any questions, concerns or would like to see details of this inventory please contact Jay Township Water Authority at 814-787-7233.

<b>Turbidity</b>						
Contaminant	MCL	MCLG	Level Detected	Sample Date	Violation Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement	0	0.288 NTU	12/3/24	N	Soil runoff
	TT= at least 95% of monthly samples ≤ 0.3 NTU		100%	2024	N	

<b>Total Organic Carbon (TOC)</b>					
Contaminant	Range of % Removal Required	Range of percent removal achieved	Number of quarters out of compliance	Violation Y/N	Sources of Contamination
TOC	35%	45 – 71% (a)	0	N	Naturally present in the environment

(a) Alternative compliance criteria (ACC) used to determine compliance with the TT.

**OTHER VIOLATIONS:** In November of 2024, we failed to monitor correctly for Distribution Chlorine, Entry Point Chlorine, and Turbidity. A Public Notification further describing these violations is attached at the end of this document.

**EDUCATIONAL INFORMATION:**

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

**OTHER INFORMATION:**

For more information, please contact Joe Uburti at (814) 787-7233.

Jay Township Water Authority  
P.O. Box 69  
49 Kennedy St.  
Byrnedale, PA 15827

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by the Jay Township Water Authority, PWSID# 6240005

## Public Notice

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE  
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

#### Monitoring Requirements Not Met for Jay Township Water Authority

Our water system violated several drinking water standards over the years. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During November 2024 we failed to monitor correctly for Distribution Chlorine, Entry Point Chlorine and Turbidity and therefore cannot be sure of the quality of our drinking water during that time.*

#### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the last year, the required sampling frequency of Distribution Chlorine, Entry Point Chlorine and Turbidity, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Distribution Chlorine	2 Samples Monthly	0	November 2024	N/A
Distribution Chlorine	2 Samples Monthly	0	November 2024	N/A
Entry Point Chlorine	Continuous	0	November 2024	N/A
Entry Point Chlorine	Continuous	0	November 2024	N/A
Turbidity	Continuous	0	November 2024	N/A
Turbidity	Continuous	0	November 2024	N/A
Turbidity(CFE)	Continuous	0	November 2024	N/A
Turbidity(IFE)	Continuous	0	November 2024	N/A

#### What happened? What was done?

*In November of 2024, we failed to monitor correctly for Distribution Chlorine, Entry Point Chlorine and Turbidity. We corrected this in the following months to remain compliant with monitoring guidelines.*

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Jay Township Water Authority at 814-787-7233.

#### Certified by:

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Print Name and Title: \_\_\_\_\_

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Enclosed in the 2024 CCR

PWS ID#: 6240005 Date distributed: \_\_\_\_\_