

2025 ANNUAL DRINKING WATER QUALITY REPORT

Rimersburg Borough Municipal Authority PWSID #: 6160012

Este informe contiene información importante acerca de su agua potable. Haga que alguien lo traduzca para usted, ó hable con alguien que lo entienda. (This report contains important information about your drinking water. Have someone translate it for you or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Dana Solida, Borough Secretary at 814-473-6519. We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Wednesday of each month at 6:30pm at 27 Main St., Rimersburg PA, 16248.

SOURCE OF WATER: We purchase water from the Borough of East Brady, which has three water supply wells located in the area between Verner Street and the Allegheny River. Their entry point sample results are noted in the tables below.

A Source Water Assessment of our source was completed by the PA Department of Environmental Protection (Pa. DEP). A summary report of the Assessment is available on the Source Water Assessment Summary Reports eLibrary web page: www.elibrary.dep.state.pa.us/dsweb/View/Collection-10045. Complete reports were distributed to municipalities, water suppliers, local planning agencies and PADEP offices. Copies of the complete report are available for review at the Pa. DEP Northwest Office in Meadville, PA. Regional Office, Records Management Unit at (814) 332-6945.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the *Safe Drinking Water Hotline* (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2025. The State allows us to monitor some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Level 1 Assessment – A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment – A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.

Mrem/year = millirems per year (a measure of radiation absorbed by the body)

pCi/L = picocuries per liter (a measure of radioactivity)

ppt (ng/l) = parts per trillion, or nanograms per liter

ppb = parts per billion, or micrograms per liter (µg/L)

ppm = parts per million, or milligrams per liter (mg/L)

Entry Point Disinfectant Residual (East Brady) 2025							
Contaminant	Minimum Disinfectant Residual	Lowest Level Detected	Range of Detections	Units	Lowest Sample Date	Violation Y/N	Sources of Contamination
Chlorine	1.00	0.05*	0.05*-1.83	ppm	6/27/25	N	Water additive used to control microbes.

*Although this Lowest Level Detected is below the Minimum Disinfectant Residual the required level was reached within the required 4-hour time frame.

DETECTED SAMPLE RESULTS

Chemical Contaminants								
Contaminant	MCL	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Chlorine (Rimersburg Distribution)	MRDL =4.0	MRDLG =4	1.51 (Feb. 2025)	1.00-1.51	ppm	2025	N	Water additive used to control microbes
Barium (East Brady)	2	2	0.0748	0.0701-0.0748	ppm	4/18/24	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Nitrate (East Brady)	10	10	0.83	N/A	ppm	2/6/25	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Perfluorooctan esulfonic acid (PFOS) (East Brady)	18	14	3.678 (Average of 4 samples)	3.14-4.36	(ppt)	2025	N	Discharge from manufacturing facilities and runoff from land use activities
Perfluorooctan oic acid (PFOA) (East Brady)	14	8	4.615 (Average of 4 samples)	3.87-5.36	(ppt)	2025	N	Discharge from manufacturing facilities and runoff from land use activities
Haloacetic Acids (HAA) (Rimersburg)	60	N/A	4.25	N/A	ppb	9/8/25	N	Byproduct of drinking water disinfection
TTHMs [Total Trihalomethanes] (Rimersburg)	80	N/A	10.40	N/A	ppb	9/17/25	N	Byproduct of drinking water chlorination
Xylenes* (Rimersburg)	10	10	0.00249*	N/A	ppm	7/28/22	N	Discharge from petroleum factories; Discharge from chemical factories

*This detection is a result from our water storage tank rehabilitation in 2022.

Lead and Copper (2025) Rimersburg								
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	Range of Tap Sampling Results	Units	# of Sites Above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead	15	0	3.55	0.00-18.3	ppb	1 out of 10	N	Corrosion of household plumbing systems; Erosion of natural deposits
Copper	1.3	1.3	0.277	0.0156-0.453	ppm	0 out of 10	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Rimersburg Borough Municipal Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested contact The Rimersburg Borough Municipal Authority at 814-473-6519. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

The Rimersburg Borough Municipal Authority prepared a service line inventory that includes the type of material contained in each service line in our distribution system. This inventory can be accessed online at <https://rimersburgborough.com/municipal-authority> or by contacting our office at 814-473-6519.

VIOLATIONS: During 2025 we failed to sample correctly for some contaminants. In January we sampled for distribution chlorine weekly as we should, but reported one weekly distribution chlorine sample late. We sampled for Trihalomethanes and Haloacetic Acids but did not collect the samples +/- 3 days from August 15, 2025 as we were required to do. In August we sampled for Total Coliform at one distribution location, but failed to sample at the second location. Since we failed to sample at the second distribution location for Total Coliform, we also failed to sample for chlorine at that location. In November we sampled for Total Coliform at one distribution location, but failed to sample at the second location. A public notification describing these violations is attached to the end of this report.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

- Inorganic contaminants, such as salts and metals, can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's *Safe Drinking Water Hotline* (800-426-4791).

Public Notice

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Rimersburg Borough Municipal Authority

Our water system violated several drinking water standards over the years. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2025 we failed to monitor correctly for Distribution Chlorine, Total Coliform, Trihalomethanes, and Haloacetic Acids; therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminants we did not properly test for during the last year, the required sampling frequency of Distribution Chlorine, Total Coliform, Trihalomethanes, Haloacetic Acids, how many samples we took, when samples should have been taken, and the date on which corrective action samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were taken
Distribution Chlorine	Weekly and at Total Coliform Sampling Location	0	August 2025	N/A
Trihalomethanes	Annual	1	August 15 +/- 3 days	9/29/25
Haloacetic Acids	Annual	1	August 15 +/- 3 days	9/20/25
Total Coliform	2 samples monthly	1	August 2025	N/A
Total Coliform	2 samples monthly	1	November 2025	N/A

What happened? What was done?

During 2025 we failed to sample correctly for some contaminants. In January we sampled for distribution chlorine weekly as we should, but reported one weekly distribution chlorine sample late. We sampled for Trihalomethanes and Haloacetic Acids but did not collect the samples +/- 3 days from August 15, 2025 as we were required to do. In August we sampled for Total Coliform at one distribution location, but failed to sample at the second location. Since we failed to sample at the second distribution location for Total Coliform, we also failed to sample for chlorine at that location. In November we sampled for Total Coliform at one distribution location, but failed to sample at the second location. We corrected this in the following months to remain compliant with monitoring guidelines.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

For more information regarding this notice, please contact Rimersburg Borough Municipal Authority at 814-473-6519.

Certified by:

Signature: _____ Date: _____

Print Name and Title: _____

As a representative of the Public Water system indicated above, I certify that public notification addressing the above violation was distributed to all customers in accordance with the delivery requirements outlined in Chapter 25 PA Code 109 Subchapter D of the Department of Environmental Protection (DEP's) regulations. The following methods of distribution were used: Enclosed in the 2025 CCR

PWS ID#: 6160012 Date distributed: _____