

2025 ANNUAL DRINKING WATER QUALITY REPORT
KITTANNING SUBURBAN JOINT WATER AUTHORITY
PWSID #: 5030043

Este informe contiene información muy importante sobre su agua de beber. Tradúzcalo ó hable con alguien que lo entienda bien. (This report contains very important information about your drinking water. Translate it or speak with someone who understands it.)

WATER SYSTEM INFORMATION:

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Kittanning Suburban Joint Water Authority at 724-545-6395. We want you to be informed about your water supply. If you want to learn more, please call the office to be placed on the agenda to attend our regularly scheduled meetings. They are held the third Tuesday of each month at 4:30 pm at the Authority Office, 710 Tarrtown Road, Adrian PA 16210.

SOURCE(S) OF WATER:

Our water source is the Allegheny River. Additionally, we rely on two underground wells as an alternate source. A Source Water Assessment of our source was completed in 2003 by the PA Department of Environmental Protection (PADEP). The Assessment has found that our source is potentially most susceptible to industrial discharges along the Allegheny River upstream of our intake, storm water and combined sewer discharges, small craft marinas located along the Allegheny River and potential contamination from accidental spills along roads within our watershed. Overall, our source has potentially moderate to significant contamination susceptibility. Summary reports of the Assessment are available by writing to Kittanning Suburban Joint Water Authority, 710 Tarrtown Road, Adrian PA 16210 and will be available on the PADEP website at www.dep.state.pa.us (directLINK "source water"). Complete reports were distributed to municipalities, water suppliers, local planning agencies and PADEP offices. Copies of the complete report are available for review at the PADEP Northwest Regional Office, Records Management Unit at 814-332-6945.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

MONITORING YOUR WATER:

We routinely monitor for contaminants in your drinking water according to federal and state laws. **The following tables show the results of our monitoring for the period of January 1 to December 31, 2025.** The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

DEFINITIONS AND ABBREVIATIONS:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

pCi/L = picocuries per liter (a measure of radioactivity)

ppb = parts per billion, or micrograms per liter ($\mu\text{g}/\text{L}$)

ppm = parts per million, or milligrams per liter (mg/L)

DETECTED SAMPLE RESULTS:

Chemical Contaminant	MCL in CCR units	MCLG	Highest Level Detected	Range of Detections	Units	Sample Date	Violation Y/N	Sources of Contamination
Nitrate (ppm)	10	10	0.64		ppm	2/24/25	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total trihalomethanes] (ppb)	80	n/a	76	22-76	ppb	8/13/25	N	By-product of drinking water chlorination
Haloacetic Acids (HAA) (ppb)	60	n/a	55	12.5-55	ppb	8/13/25	N	By-product of drinking water disinfection
Chlorine (ppm) Distribution	MRDL = 4	MR DLG = 4	2.50	.21-2.50 mg/1	ppm	10/2/25	N	Water additive used to control microbes
Total organic carbon (ppm)	TT	n/a	62% removal				N 33% required	Naturally present in the environment
Chlorine (ppm) Entry Point	TT = 0.2	TT = 0.2	Lowest level detected 1.26	1.26-2.44	ppm	8/27/25	N	Water additive used to control microbes

Contaminant	Action Level (AL)	MCLG	90th Percentile Value	Range of tap sampling results	Units	# of Sites above AL of Total Sites	Violation Y/N	Sources of Contamination
Lead 2025	15	0	0	0-1.11	ppb	0	N	Corrosion of household plumbing
Copper 2025	1.3	0.389	0.105	0-.161	ppm	0	N	Corrosion of household plumbing

Kittanning Suburban Joint Water Authority continues to prepare a service line inventory of our system that includes the type of materials contained in service lines in our distribution system. This inventory can be accessed by contacting our office at 724-545-6395.

Contaminant	MCL	MCLG	Level Detected	Sample Date	Violation of TT Y/N	Source of Contamination
Turbidity	TT=1 NTU for a single measurement	0	.238 NTU	11/8/2025	N	Soil Runoff
	TT=at least 95% of monthly samples <0.3 NTU		100%	100%		

VIOLATIONS:

An error with the water treatment plant's communication system led to a failure in WTP alarms and shutdowns. An operator noticed levels of chlorine at the treatment plant above the maximum residual disinfectant level "MRDL" and shut off the service pumps to the distribution. KSJWA consulted with the DEP Safe Drinking Water Program and collected chlorine samples in the distribution system. Distribution samples were within compliance (below the MRDL of 4.0 mg/L). KSJWA flushed the overchlorinated water out of the water treatment plant, adjusted chemical settings appropriately, and resumed operations. There was no interruption of service or evidence of chlorine above the MRDL in the distribution system.

ADDITIONAL TESTING

We continue to monitor for disinfection by-products (TTHM's and HAA5's) on a quarterly basis.

EDUCATIONAL INFORMATION:

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater run-off, industrial or domestic wastewater discharges, oil and gas production,

- mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
 - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
 - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

INFORMATION ABOUT LEAD:

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

Kittanning Suburban Joint Water Authority is responsible for providing high quality drinking water and will remove lead pipes, if found, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use an American National Standards Institute certified filter to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Kittanning Suburban Joint Water Authority at 724-545-6395. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.