

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

Monitoring Requirements Not Met for Conyngham Water Co.

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the first quarter of 2013 we did not sample for VOC's at entry point 108 and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for Volatile Organic Compounds (VOC's) and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
VOC	1 Sample/Quarterly	0	1 st Quarter of 2013	2 nd Quarter of 2013

What happened? What was done?

The sample was taken in the next quarter with satisfactory results.

For more information, please contact Eddie Gregory at the Conyngham Borough Authority at (570) 788-0608.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you via the internet, also hard copies are available at the Conyngham Borough Authority office Monday-Friday 8-4. A list of contaminants that are included in VOC testing and it's results are included with this report.

PWS ID#: 2400048

Date distributed: 6/27/2014



Results Report

Order ID: 13062162

Conyngham Borough Authority
PO Box 469
Conyngham, PA 18219
Attn: Ed Gregory, primary

Project: Quarterly SDWA Analysis
66 South Main Street
Sugarloaf, PA 18249
PWSID: 2400048

Sample Number: 13062162-01	Site: 108 EP	Customer Sample ID:							
Collector: ACK-SWTL	Collect Date: 6/24/2013	10:32 AM	Sample Type: E						
Department / Test / Parameter	Result	Units	Method	R.L.	Prep Date	By	Analysis Date	By	

Organics

21 Regulated VOCs

Benzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Carbon Tetrachloride	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Chlorobenzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,2-Dichlorobenzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,4-Dichlorobenzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,2-Dichloroethane	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,1-Dichloroethene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
cis-1,2-Dichloroethene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
trans-1,2-Dichloroethene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Dichloromethane (Methylene Chloride)	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,2-Dichloropropane	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Ethyl Benzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Styrene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Tetrachloroethene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Toluene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,2,4-Trichlorobenzene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,1,1-Trichloroethane	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
1,1,2-Trichloroethane	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Trichloroethene	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Vinyl Chloride	<0.5	ppb	EPA 524.2	0.5	06/26/13 15:51	RCS2
Total Xylenes	<1.0	ppb	EPA 524.2	1	06/26/13 15:51	RCS2

Surrogate Recoveries	Results	Units	% Recovery	Method	Limits (% Recovery)
Bromofluorobenzene	4.78	µg/L	96	EPA 524.2	70 - 130
1,2-Dichlorobenzene-d4	5.08	µg/L	102	EPA 524.2	70 - 130

Comments: