

2024 Annual Drinking Water Quality Report

Snake Spring Township Municipal Authority

As your public drinking water supplier (Public Water Supply ID Number 4050038), the Snake Spring Township Municipal Authority (SSTMA) is pleased to present to you our Consumer Confidence Report for the 2024 operating year. This report provides you with information about the quality of water and the services we deliver to you every day. We constantly strive to provide you with a safe and dependable supply of drinking water. We want you to understand the constant effort we make to continually protect our water sources and improve the quality of water supplied to you. We are committed to ensuring the quality and consistency of your water.

THE SOURCES of water for our public water supply include two groundwater wells. Both wells are located in the Lutzville area of Snake Spring Township and are known as the Pittman Tract Wells. Construction of the wells, the water storage facilities and water distribution system were completed in early 2007. Startup of the wells and water system began in May of 2007. The SSTMA water system consists of approximately 3.5 miles of water transmission and distribution lines, two water storage tanks (Mile Level and Hospital Hill), two production wells and a well station that houses the metering, treatment, and system monitoring equipment. The Mile Level and Hospital Hill storage tanks have capacities of 300,000 gallons each. Treatment of the raw water from the Pittman well sources includes disinfection through the addition of chlorine and corrosion control through the addition of a polyphosphate corrosion inhibitor. No other treatment is necessary or required at this time.

In combination, the Pittman Tract wells are capable of supplying up to 288,000 gallons per day. In order to ensure that uninterrupted water service may be supplied to its customers in the event of a power outage the water plant at the Pittman Tract Well site is equipped with an emergency generator that is capable of providing continuous operation of both well pumps, the pump control system and water treatment equipment until utility power would be restored.

SOURCE WATER ASSESSMENT: A Source Water Assessment has not yet been completed by the PA Department of Environmental Protection (PA DEP) for the Snake Spring Township Municipal Authority water supply. However, information on the PA DEP source water assessment program and the current status of assessments being conducted is available from the PA DEP website at:

<http://www.depgreenport.state.pa.us/elibrary/GetFolder?FolderID=4490>

WATER QUALITY was monitored during the operating period between January 1, and December 31, 2024. The Authority routinely monitors for contaminants in your drinking water according to Federal and State laws.

"Water Is a Valuable Resource - Please Use It Wisely"



2024 Water Quality Report

Snake Spring Township Municipal Authority

THE SOURCES OF DRINKING WATER (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and Herbicides**, which may come from a variety of sources such as agriculture, urban storm water runoff and residential uses.
- **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- **Radioactive Contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

SOME PEOPLE MAY BE MORE VULNERABLE to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA / CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline: (1-800-426-4791).

DRINKING WATER, INCLUDING BOTTLED WATER, may reasonably be expected to contain at least small amounts of some contaminants. The presence of some contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

IN ORDER TO ENSURE THAT TAP WATER IS SAFE TO DRINK, EPA and DEP prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration and DEP regulations establish limits for contaminants in bottled water which must provide the same protection for public health. The following table shows the results of our water quality monitoring for the period of January 1st through December 31, 2024. In reviewing this table, it should be noted that the State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Therefore, some of the data may be from previous years in accordance with the Safe Drinking Water Act. The date of sampling has been noted on the following sampling results table. Only those contaminants detected in the Authority's water are listed in the table.

2024 Water Quality Report – Snake Spring Township Municipal Authority
Detected Regulated Contaminant Table

Contaminant (Unit of Measure)	MCL	MCLG	Highest Level Detected	Range	Sample Period	Violation? (Yes-No)	Likely Source of Contamination
Disinfectant Residuals and Disinfection By-Products							
Chlorine (ppm) <i>Distribution System</i>	MRDL = 4	MRDLG = 4	1.41	1.00 to 1.41	2024 (Highest mo. February)	No	Water additive used to control microbes
Chlorine (ppm) <i>Entry Point</i>	Minimum required residual = 0.4	MRDLG = 4	Lowest residual recorded = 0.54	0.54 to 1.98	2024 (08/12/2024 lowest)	No	Water additive used to control microbes
Total Haloacetic Acids (ppb)	60	NA	2.07	NA-one sample analyzed	July 09, 2024	No	Byproduct of drinking water disinfection
TTHMs- Total Trihalomethanes (ppb)	80	NA	11.1	NA – one sample analyzed	July 09, 2024	No	Byproduct of drinking water disinfection
Inorganic Contaminants (Pittman Well Sources Entry Point)							
Nitrate (ppm) <i>Entry Point</i>	10	10	3.33	NA – one sample analyzed	07/10/24	No	Fertilizer Run-off, leaching from septic tanks and sewage, erosion of natural deposits
Barium (ppm) <i>Entry Point</i>	2	2	0.0732	NA - one sample analyzed	07/10/24	No	Discharge of drilling waste: discharge from metal refineries; erosion of natural deposits
Nickel (ppm) <i>Entry Point</i>	NA	NA	0.00264	NA-one sample analyzed	07/10/24	No	Erosion of natural deposits; Discharge from industrial processes
Organic Contaminants <i>Entry Point 101</i>							
Perfluorobutanesulfonic Acid (PFBS)	500	NA	47	NA-One sample analyzed	11/20/24	No	Discharge from manufacturing facilities and runoff from land use activities
Lead and Copper (Distribution System)							
Contaminant	Action Level (AL)	MCLG	90 th Percentile Value	# Sites Above AL of Total Sites	Sample Date	Violation? (Yes/No)	Source of Contamination
Lead (ppb)	15	0	0.85	No sites were above the AL out of 10 sites tested	2022	No	Corrosion of household plumbing systems, Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.157	No sites were above AL out of 10 sites tested	2022	No	Corrosion of household plumbing systems, Erosion of natural deposits; Leaching from wood preservatives

Information about Lead –

Lead: Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Snake Spring Township Municipal Authority is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact the Snake Spring Township Municipal Authority at (814) 623-2627. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at www.epa.gov/safewater/lead.

Additionally, a service line inventory has been prepared for the Snake Spring Township Municipal Authority. Customers can access this information by contacting the Snake Spring Township Municipal Authority at (814) 623-2627

VIOLATIONS – There were no violations for the Snake Spring Township Municipal Authority in 2024.

Additional testing - Additional contaminants are regulated and are also routinely tested for, but are not present at detectable limits. Additional contaminants that were tested for in 2024, or in previous years, but were **not detected** in the Authority's system included:

- **Microbial Contaminants** (2024-Distribution System) – Total coliform bacteria
- **Inorganic Contaminants** (2024-Entry Point) – Arsenic, Cadmium, Chromium, Cyanide (Free), Fluoride, Mercury, Nickel, Selenium, Antimony, Beryllium, Thallium; (2023) Nitrite
- **Disinfection By-Products** (2024-Distribution System) – Monochloroacetic Acid, Trichloroacetic Acid, Monobromoacetic Acid, Dibromoacetic Acid, Bromoform
- **Volatile Organic Compounds** (2024-Entry Point) – cis-1,2-Dichloroethylene; trans-1,2-Dichloroethylene; Dichloromethane; 1,2-Dichloropropane; Ethylbenzene; Styrene; Tetrachloroethylene; 1,1,1-Trichloroethane; 1,1,2-Trichloroethane; Trichloroethylene; Toluene; Xylenes (total); Benzene; Carbon tetrachloride; Chlorobenzene; o-Dichlorobenzene; p-Dichlorobenzene; 1,2-Dichloroethane; 1,1-Dichloroethylene; 1,2,4-Trichlorobenzene; vinyl chloride
- **Synthetic Organic Compounds** – (2024-Entry Point) Endrin; Lindane; Methoxychlor, Toxaphene; Dalpon; Diquat; Endothall; Glyphosate; Di(2-ethylhexyl) Adipate; Oxymal; Simazine; Di(2-ethylhexyl) Phthalate; Atrazine, Piclorem; 2,4-D; Dinoseb; Hexachlorocyclopentadiene; Carbofuran; Alachlor; 2,4,5-TP Silvex; Hexachlorobenzene; Benzo(a)pyrene; Pentachlorophenol; 1,2-Dibromo, 3-chloropropene; Ethylene Dibromide; Heptachlor; Heptachlor Epoxide; Chlordane; PCBs and Dioxin
- **Radioactive contaminants** (2017-Entry Point) – Gross alpha emitters; Radium-226; Radium-228; Combined Uranium

Glossary

In the preceding Table, and throughout this report, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level (AL) - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

CDC – Centers for Disease Control

DEP – Pennsylvania Department of Environmental Protection

EPA – US Environmental Protection Agency

Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) -The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

NA – Not Applicable

ND – Not Detected

ppb - Parts per billion or micrograms per liter

ppm - Parts per million or milligrams per liter

SSTMA – Snake Spring Township Municipal Authority

- PLEASE CONSERVE OUR WATER RESOURCES -

The Snake Spring Township Municipal Authority requests that customers conserve our water resources by conserving water in the home and at places of work. Efficient water use can have major environmental, public health, and economic benefits by helping to improve water quality, maintain aquatic ecosystems, and protect drinking water resources. Efficient use of water, through behavioral, operational, or equipment changes, if practiced broadly can help mitigate the effects of drought. Efficiency measures can also save the homeowner money on their water and energy bills. The following facts, tips and suggestions were obtained from **Think2onow** and the EPA **Watersense** websites and can help you conserve water, save money and protect and preserve our water resources. For many more water saving tips and water conservation resources, please visit their websites at www.think2onow.com or www.epa.gov/watersense.

Water Conservation Facts


1. Less than 2% of the Earth's water supply is fresh water.
2. Of all the earth's water, 97% is salt water found in oceans and seas.
3. Only 1% of the earth's water is available for drinking water. Two percent is frozen.
4. The human body is about 75% water.
5. A person can survive about a month without food, but only 5 to 7 days without water.
6. Every day in the United States, we drink about 110 million gallons of water.
7. Showering and bathing are the largest indoor uses (27%) of water domestically.
8. If every household in America had a faucet that dripped once each second, 928 million gallons of water a day would leak away.
9. A leaky faucet can waste 100 gallons a day.
10. One flush of the toilet uses 3 ½ gallons of water (on average).
11. An average bath requires 37 gallons of water.
12. An average family of four uses 881 gallons of water per week just by flushing the toilet.
13. The average 5-minute shower takes 15-25 gallons of water--around 40 gallons are used in 10 minutes.
14. You use about 5 gallons of water if you leave the water running while brushing your teeth.
15. If you water your grass and trees more heavily, but less often, this saves water and builds stronger roots.
16. An automatic dishwasher uses 9 to 12 gallons of water while hand washing dishes can use up to 20 gallons.
17. Approximately 1 million miles of pipelines and aqueducts carry water in the U.S. & Canada. That's enough pipe to circle the earth 40 times.
18. About 800,000 water wells are drilled each year in the United States for domestic, farming, commercial, and water testing purposes.
19. You can refill an 8-oz glass of water approximately 15,000 times for the same cost as a six-pack of soda pop.
20. A dairy cow must drink four gallons of water to produce one gallon of milk.
21. 300 million gallons of water are needed to produce a single day's supply of U.S. newsprint.
22. One inch of rainfall drops 7,000 gallons or nearly 30 tons of water on a 60' by 180' piece of land.
23. A gallon of gasoline takes nearly 13 gallons of water to produce. Combine your errands, car pool to work, or take public transportation to reduce both your energy and water use.
24. A cross-country airplane trip (about 6,000 miles) could be worth more than 1,700 standard toilet flushes.
25. According to recent reports, nearly 5% of all U.S. water withdrawals are used to fuel industry and the production of many of the material goods we stock up on weekly, monthly, and yearly.

26. It takes about 100 gallons of water to grow and process a single pound of cotton, and the average American goes through about 35 pounds of new cotton material each year.
27. Try this water calculator to see how you are doing:

<http://www.home-water-works.org/calculator>

Other Resources:

- [American Water Works Association](http://www.awwa.org/) (<http://www.awwa.org/>)
- [Green Plumbers](http://www.greenplumbersusa.com/) (<http://www.greenplumbersusa.com/>)
- [Earth Easy](http://eartheasy.com/water-conservation) (<http://eartheasy.com/water-conservation>)
- [Alliance for Water Efficiency](http://www.allianceforwaterefficiency.org/) (<http://www.allianceforwaterefficiency.org/>)
- [EPA Water Sense](http://www.epa.gov/watersense/) (<http://www.epa.gov/watersense/>)
- [USGS Water](http://www.usgs.gov/water/) (<http://www.usgs.gov/water/>)



Save Indoors



You've purchased some [WaterSense labeled products](#) and started down the road to savings, but don't stop there. There are lots of things you can do in your own home to reduce water use and get more from less. Just follow our simple tips below to get started!

Fix a leak:

Small household leaks can add up to gallons of water lost every day. That's why WaterSense reminds Americans to check their plumbing fixtures and irrigation systems each year in March during [Fix a Leak Week](#).

In the bathroom—where over half of all water use inside a home takes place:

- Turn off the tap while shaving or brushing teeth.
- Showers use less water than baths, as long as you keep an eye on how long you've been lathering up. Learn tips on how to [Shower Better](#).
- If you're dreaming of a [Better Bathroom](#), get ready for your mini-makeover.
- [Calculate how much you can save](#) with WaterSense labeled products in the bathroom!

In the kitchen—whip up a batch of big water savings:

- Plug up the sink or use a wash basin if washing dishes by hand.
- Use a dishwasher—and when you do, make sure it's fully loaded!
- Scrape your plate instead of rinsing it before loading it into the dishwasher.
- Keep a pitcher of drinking water in the refrigerator instead of letting the faucet run until the water is cool.
- Thaw in the refrigerator overnight rather than using a running tap of hot water.
- Add food wastes to your compost pile instead of using the garbage disposal.

In the laundry room—where you can be clean AND green:

- Wash only full loads of laundry or use the appropriate water level or load size selection on the washing machine.
- To save money on your energy bills, set your washing machine to use cold water rather than hot or warm water.

Save Outdoors

Of the estimated 29 billion gallons of water used daily by households in the US, nearly 9 billion gallons, or 30 percent, is devoted to outdoor water use. In the hot summer months, or in dry climates, a household's outdoor water use can be as high as 70 percent.

- [Create a water-smart landscape](#) that is both beautiful and efficient to give your home the curb appeal you desire.
- Timing is everything! Knowing when and how much to water allows you to keep a [healthy landscape](#).
- Upgrade to a WaterSense labeled controller if you have an [in-ground irrigation system](#).
- Find a certified irrigation professional to install, maintain, or audit your irrigation system to ensure it is watering at peak efficiency.
- Sweep driveways, sidewalks, and steps rather than hosing off.
- Wash the car with water from a bucket, or consider using a commercial car wash that recycles water.
- If you have a pool, use a cover to reduce evaporation when the pool is not being used.
- Take action during the [hot summer months](#) when water use increases to curb water waste. Get the facts on water use when it's hot.
- If a [drought](#) is declared in your area, go the extra mile to save water.

Save Energy

It takes a lot of energy to deliver and treat the water you use every day for bathing, shaving, cooking, and cleaning. Homes with electric water heaters, for example, spend one-quarter of their electric bill just to heat water. As an example, letting your faucet run for five minutes uses about as much energy as letting a 60-watt light bulb run for 14 hours.

Drops & Watts: You Can't Have One Without the Other

On average, the annual energy used to deliver and treat water for only 10 households could power a refrigerator for more than two years. In some areas of the country, that estimate is very low. Heating water for showering, bathing, shaving, cooking, and cleaning also requires a considerable amount of energy. Homes with electric water heaters, for example, spend one-fourth of their total electric bills.

Did you Know?

It also takes water to create energy. Vast amounts of water are used to cool the power plants that generate electricity. In fact, it takes 3,000 to 6,000 gallons of water to power a 60-watt incandescent bulb for 12 hours per day over the course of a year. One of the simplest ways to save both water and energy is to install water-efficient products. WaterSense labeled products not only save water, but can help reduce your energy bills. Installing WaterSense labeled faucet aerators in your bathrooms, for example, costs just a few dollars but could save you enough electricity to dry your hair every day for a year! You can be sure the products will not only save resources, but will perform well. All WaterSense labeled products are tested and independently certified to ensure they meet EPA's criteria for both efficiency and performance.

Please help us find leaks, save water and reduce water service costs... Because water lines are located underground, leaks may go unnoticed for days and even years resulting in a considerable waste of our valuable water resource and additional costs for all customers. Please help us locate these leaks by reporting to the Water Department any occurrences of: water running in locations that are normally dry; wet spots in yards and streets; the sound of water running in your home when water is not in use; the sound of water trickling or running in a storm inlet when it is not raining; sudden or unusually low water pressure; and slugs of discolored or cloudy water. When an occurrence such as this is reported, a representative of the water department will make contact and investigate the situation.

Snake Spring Township Municipal Authority
624 Pennknoll Road
Everett PA 15537

2024 Annual Drinking Water Quality Report Snake Spring Township Municipal Authority

This report shows our water quality and what it means. **IF YOU HAVE ANY QUESTIONS ABOUT THIS REPORT** or questions concerning your water utility, please contact Mr. Joshua Baker, Water System Operator, at (814) 623-2627, Monday through Friday, 7 AM to 3 PM, excluding holidays. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled Authority meetings which are held at 7 PM on the second Monday of each month. The meetings are held at the Snake Spring Municipal Authority Building at 624 Pennknoll Road, Everett PA.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.